# DOCKER 150

Heavy Duty LED floodlight designed to replace HID lighting in applications requiring high performance and high durability.

Electronic: LED control gear driving 32 LEDs at 1.4A with symmetrical and Asymmetrical distributions. IP66, Class I protection with 6 kV Surge Protection.

Body: recyclable, extruded aluminium and powder -

coated AISI 316 stainless steel.

Optic Enclosure: PMMA Weather-proof lenses.



Performance	
Luminaire Output	Up to 17.500 lm
Power Absorption	145 W
Lumen Maintenance [L80 B10]	119.000h
Lumen Maintenance [L70 B50]	190.000h

Optoelectronics	
CRI	70 - 80 - 90
Colour Temperature	<ul><li>3000K Warm White</li><li>4000K Neutral White</li><li>5000K Pure White</li><li>5700K Cool White</li></ul>
Secondary Optics	Weather proof, Anti-yellowing PMMA refraction matrix
No of LEDs	32

No of LEDs	32
Luminaire Body	
Chassis and Bracket	AISI 316 Stainless Steel
Metal Finish	Powder Coating
Heatsinks	Anodized Extruded Aluminium (Copper Content <0.1%)
Bracket	Customisable AISI 316
Weight	8 kg
Dimensions (L-W-H)	201L x 255W x 196H
Protection Level	IP67
Impact Resistance	IK09

Weight	8 kg
Dimensions (L-W-H)	201L x 255W x 196H
Protection Level	IP67
Impact Resistance	IK09
Vibrations Resistance	
ANSI C136.31-2010	Up to 6G for 100.000 cycles
Corrosion Resistance	
UL 1598A:2000	Salt Spray ASTM B117 for 1000 hours with 5% salinity
Electronics	
Voltage input	100 - 305 VAC 50-60Hz
Active Power F.C.	0.97



Midstream Lighting Ltd, 1 Chesham Street, London SW1X 8ND UK Tel +44 207 584 8310 Email info@midstreamlighting.com www.midstreamlighting.com



Surge Protection	10kV line-earth, 6kV line-line
Insulation class	IEC Class I
Short Circuit Protection	Auto-recovery
Over Heat Protection	Drops output current
Operation Conditions	
Working temperature	-40°C/+50°C
Humidity Range	0% - 94%

#### Normative reference

EN 60598-1: 2015 - Luminaires - Part 1: General requirements and tests EN 60598-2-5: 2015 Luminaires - Part 2-5: Particular requirements - Floodlights EN 62031: 2008 + A2:2015 - LED modules for general lighting - Safety specifications

EN 60598-2-3: 2003 + A1: 2011 - Luminaires - Part 2-3: Particular requirements - Luminaires for road and street lighting

EN 62493: 2015 Assessment of lighting equipment related to human exposure to electromagnetic fields EN 60529: 1992 + A2: 2013 - Degrees of protection provided by enclosures (IP Code)

IEC 60069-2-52: 1996 Environmental test - Part 2:Tests - Test Kb - Salt mist cyclic (sodium

chloride solutions)

EN 55015: 2013 + A1: 2015 - Limits and methods of measurement of radio disturbance characteristics of electrical lighting and similar equipment EN 61547: 2009 - Equipment for general lighting purposes - EMC immunity requirements

EN 61000-3-2: 2014 - Electromagnetic compatibility (EMC) - Part 3-2: Limits - Limits for harmonic current emissions (equipment input current  $\leq$  16 A per phase) EN 61000-3-3: 2013 - Electromagnetic compatibility (EMC) - Part 3-3: Limits - Limitation of voltage changes, voltage fluctuations and flicker in public low-voltage supply systems, for equipment with rated current  $\leq$  16 A per phase and not subject to conditional connection

EN 61643-11: 2012 - Low-voltage surge protective devices. Part 11: Surge protective devices connected to low-voltage power systems - Requirements and test methods

IEEE C62.41.2-2002 - Recommended practice on characterization of surges in low-voltage AC power EN 61547: 2009 - Equipment for general lighting purposes - EMC immunity requirements

EN 61000-3-2: 2014 - Electromagnetic compatibility (EMC) - Part 3-2: Limits - Limits for harmonic current emissions (equipment input current  $\leq$  16 A per phase) EN 61000-3-3: 2013 - Electromagnetic compatibility (EMC) - Part 3-3: Limits - Limitation of voltage changes, voltage fluctuations and flicker in public low-voltage supply systems, for equipment with rated current  $\leq$  16 A per phase and not subject to conditional connection

EN 61643-11: 2012 - Low-voltage surge protective devices. Part 11: Surge protective devices connected to low-voltage power systems - Requirements and test methods.

IEEE C62.41.2-2002 - Recommended practice on characterization of surges in low-voltage AC power

#### **Dimensions**









DOCKER 150

### **Photometrics**


FH









S2




S3



S4



S5



## Ordering codes

Product Family	Power	Optic	ССТ	CRI	Voltage Input	Control System	Body Type	Bracket	Optional
D (Docker)	15	FH	A (5000k)	70	EU (100-277 VAC)	10 (O-10v)	M (AISI 316 SS)	A (Type A)	00
		S1	B (4000k)	80	US (277-480 VAC)	00 (No Control)		B (Type B)	
		S2	C (3000K)	90					
		S3	D (5700k)						
		S4							
		S5							

Example: D15FHA70EU10MA00

